Ditwyler Cabl

Kabelabschottung " der Feuerwiderstandsdauer S 90 nach Zul.-Nr.: Z-



Product information

Application

Used to form a bulkhead for cable wall and ceiling penetration, against the effects of fire for a period of 90 minutes in accordance with DIN 4102-9 (fire resistance class S90).

Article No.	Bulkhead	Application	Info
1300 469	Fire protection brick	For provision of a square	Packaging comprises 20 pieces
	pyrosys [®] TS90	S90 bulkhead in ceilings and	dry and dust-free assembly,
		walls in accordance with DIN 4102-9	problem free installation
			Volume app. 220 x 120 x 60 mm
1300 477	Fire protection block	For closing gaps	Set consists of 12 cartridges
	pyrosys [®] TS90	and spandrels and	310ml cartridge, white
		wall soffits	
1300 478	Identification sign	For permanent identification	Set consists of 10 identification
	Fire protection plug	of a cable fire wall,	signs
	Fire protection brick	DIN 4102-9	

Dätwyler Cables

Preventive fire protection

Fixing devices

Informations